

Sample Date	Test Report No	Location	Sample 1									
Regulatory Levels			< 200	< 2	< 10	< 3000	< 20	<=10µg/l	<=5.0µg/l	<=5.0µg/l	<=4	6.5-9.5
			Iron	Copper	Lead	Zinc	Nickel	Arsenic	Cadmium	Chromium	Turbidity	Ph
			Units	µg/l	mg/l	µg/l	µg/l	µg/l	µg/l	µg/l	NTU(FTU)	PH Units
19/11/2018	70620471	School Kitchen (Shared)	<13	3.680	<0.1	32	<1.3	<0.9	<0.10	<1.0	0.6	7.56
19/11/2018	70620468	Home Economics (Buchanan High)	36	7.489	0.5	32	<1.3	<0.9	<0.10	<1.0	4.4	8.35
19/11/2018	70620469	Water Cooler (St Ambrose)	<13	0.034	<0.1	28	1.7	<0.9	<0.10	<1.0	0.3	7.19
19/11/2018	70620470	Staff Room (St Ambrose)	31	0.111	<0.1	14	<1.3	<0.9	<0.10	<1.0	15.5	7.85
13/12/2018	70622880	School Kitchen (Shared)	38	0.013	0.5	9	<1.3	<0.9	<0.10	<1.0	0.4	7.26
13/12/2018	70622881	Home Economics (Buchanan High)	36	0.061	0.2	9	<1.3	<0.9	<0.10	<1.0	0.4	7.43
11/01/2019	70623596	Staff Room Sink at Office (St Ambrose)	35	<0.011	<0.1	5	<1.3				0.4	6.68
22/02/2019	70628575	Home Economics (St Ambrose)	27	0.022	<0.1	4	<1.3				0.5	7.52
22/02/2019	70628576	Home Economics (Buchanan High)	30	0.015	<0.1	11	<0.13				0.5	7.42
22/02/2019	70628577	Staff Room (St Ambrose)	33	0.013	0.1	5	<1.3				0.4	7.36
22/02/2019	70628578	Staff Room (Buchanan High)	29	0.014	0.3	12	<1.3				0.7	7.42
22/02/2019	70628579	School Kitchen (Shared)	26	<0.011	<0.1	2	<1.3				0.7	7.34

Note-Arsenic, Chromium and Cadmium are routinely monitored for all chemical water samples and were below detection limits for all chemical water samples submitted.