SAFETYGASDETECTION

SERVICE RECORD Using Technology to Safeguard Life

Customer	North Lanarks	North Lanarkshire Counsil		ML2 2HT Townhead Rd			
Building	Main School Building		Room	Janitors Office			
Contact	Ellen Douglas	(Head) / Helen Taylor			111111111111111111111111111111111111111		
Manufacturer	SGD		S/N	120203-002			
Sys Description	Inteligent Fan	Control System					
Notes	Normal Panel	Key.					
Gas Measured	CH4%	CO2%			Sensor List:		
1st Alarm Level	1.0	1.0			No. Type	Date Due	Qty
2nd Alarm Level	2.5	2.5			Pump, Double Head	08-May- 20	1
3rd Alarm Level					CO2-Dyn		1
4th Alarm Level					CH4-Dyn CH4-Dyn		1
Calibration Functional Test					Filter, Bowl	08-May-20	1
Test Gas: #1085 : 250ppm CO	0 / 2% CO2 / 2.5%	o CH4 / 15% O2 / 80% N2					
Notes: Serviced. Pump reading 3.4 lit Download Data Logo							
Result: F	Pass						
Remedial Required?	P No						
Completed By:	Liam Colbe	ert	Name:				
Signature:	Pollar 6		Signature:	THE PT AND ADDRESS			
Next Visit Due:	08-Nov-19	Service Interval:	Date:	2-Aug-19			

For Office Use Only: St. Ambrose Glasgow North Lanarkshire School

15-Apr-20

Send To: Gerry Boyle boyleg@northlan.gov.uk