## SAFETYGASDETECTION

## SERVICE RECORD

## **Using Technology to Safeguard Life**

Customer	North Lanarkshire Counsil		Postcode	ML2 2HT Townhead Rd			
Building	Main School Building		Room	Janitors Office			
Contact	Ellen Douglas (Hea	d) / Helen Taylor					
Manufacturer	SGD		S/N	120203-002			
Sys Description	Inteligent Fan Conti	rol System					
Notes	Normal Panel Key.						
Gas Measured	CH4%	CO2%			Sensor List:		
1st Alarm Level	1.0	1.0			No. Type	Date Due	Qty
2nd Alarm Level	2.5	2.5			Pump, Double Head	08-May- 20	1
3rd Alarm Level					CO2-Dyn		1
4th Alarm Level					CH4-Dyn CH4-Dyn		1
Calibration Functional Test Downloaded Data logg Measured Pump flow r  Test Gas: #1073 : 250ppm CO /  Notes: Service - Replaced do Measured Pump flow r	rate 3.4 L/Min  2% CO2 / 2.5% CH4  uble headed pump a				NSD08/05/2020		
Result: Pa							
Completed By:	Chris Brown		Name:	1			
Signature	Boun		Signature:				
Next Visit Due:	8-Nov-19	Service Interval:	Date:	8-May-19			

 $For \ Office \ Use \ Only: \quad St. \ Ambrose \ Glasgow \ North \ Lanarkshire \ School$ 

15-Apr-20

Send To: Gerry Boyle boyleg@northlan.gov.uk